

**TEST REPORT**

DATE: 05-19-2023

Page 1 of 1

TEST NUMBER: 0296768

CLIENT	Urban Surfaces
--------	----------------

TEST METHOD CONDUCTED	ASTM F410 (Modified per ASTM F3261) Standard Test Method for Wear Layer Thickness of Resilient Floor Coverings by Optical Measurement
-----------------------	---



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	1901-2134 Mission Bay 7"x48" (4.5)
LOT NUMBER	Batch: 221129-11991
CONSTRUCTION	SPC

**GENERAL PRINCIPLE**

The thickness of the wear layer of resilient non-textile floor coverings is determined by microscopic optical measurement. The specimen is examined in five areas and measurements are made on the outer most layer of the composite material. The measurements are recorded to the .0001 inch and averaged. Only the highest thickness values are reported per ASTM F3261, avoiding values from any non-embossed areas.

**TEST RESULTS**

		THICKNESS	
	SPECIMEN 1	0.0068 inch	
	SPECIMEN 2	0.0073 inch	
	SPECIMEN 3	0.0062 inch	
	SPECIMEN 4	0.0065 inch	
	SPECIMEN 5	0.0070 inch	

AVERAGE TOTAL THICKNESS	0.0068 Inch	6.8 mil
-------------------------	-------------	---------

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.