



TEST REPORT

DATE: 06-24-2022

TEST NUMBER: 0287733

CLIENT	Urban Surfaces
--------	----------------

TEST METHOD CONDUCTED	NALFA 3.3 Xenon Light Resistance
-----------------------	----------------------------------



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	4001 Camden
LOT NUMBER	Batch: 220131-10981
CONSTRUCTION	Laminate Flooring

GENERAL PRINCIPLE

The test specimen is exposed to a predetermined amount of radiant energy under specified conditions of temperature and relative humidity. The lightfastness of the specimen is assessed by comparing the exposed and the unexposed portions of the test sample with the NALFA criteria.

TEST RESULTS

	EXPOSURE	RATING
Sample 1	396 kJ/m ²	5.0
Sample 2	396 kJ/m ²	5.0
Sample 3	396 kJ/m ²	5.0

*** Meets NALFA specified criteria for usage Levels 1, 2, 3 and 4.**

Class 1 RESIDENTIAL	Class 2 LIGHT COMMERCIAL	Class 3 COMMERCIAL	Class 4 HEAVY COMMERCIAL
No More than Slight Effect	No More than Slight Effect	No More than Slight Effect	No More than Slight Effect

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.