

**TEST REPORT****DATE: 06-24-2022****TEST NUMBER: 0287733**

CLIENT	Urban Surfaces
---------------	----------------

TEST METHOD CONDUCTED	NALFA 3.9 Chair Resistance
------------------------------	----------------------------



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	4001 Camden
LOT NUMBER	Batch: 220131-10981
CONSTRUCTION	Laminate Flooring

GENERAL PRINCIPLE

This test is designed to determine what effect the action of rolling traffic has on a particular flooring surface. The sample is subjected to the reciprocating action of a chair base which is loaded to 198 pounds total weight. The chair castors are set to cause a random cycling motion resulting in an oval shaped wear pattern. After a predetermined number of cycles, the test sample is given a numerical rating based on the general appearance.

TEST RESULTS

NUMBER OF CYCLES	APPEARANCE RATING
35,000	No Effect

*** Meets NALFA specified criteria for usage Levels 1, 2, 3 and 4.**

Class 1 RESIDENTIAL	Class 2 LIGHT COMMERCIAL	Class 3 COMMERCIAL	Class 4 HEAVY COMMERCIAL
25,000 cycles No Effect	25,000 cycles No Effect	25,000 cycles No Effect	35,000 cycles No Effect

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.