

## **TEST REPORT**

**DATE: 01-14-2025 TEST NUMBER:** 0313881

CLIENT	Urban Surfaces
--------	----------------

TEST METHOD CONDUCTED	NALFA 3.7 Wear Resistance
-----------------------	---------------------------

DESCRIPTION OF TEST SAMPLE		
IDENTIFICATION	Timber Haus	
CONSTRUCTION	8mm + 1mm Eco Pad Laminate Water Resistant	
BACKING	1mm Eco Pad	

## **GENERAL PRINCIPLE**

This test measures the ability of laminate flooring to resist abrasive wear through the décor layer. A test specimen is abraded using a dual head rotary platform Taber abrader. The initial point of wear is listed as the number of cycles completed at which visible evidence, via Tappi size chart, is noticed in 3 of 4 quadrants of the test specimen. The abrasion media is S-42 sand paper.

## **TEST RESULTS**

	INITIAL WEAR POINT RESULTS	
Specimen 1	7,000 Cycles	
Specimen 2	7,200 Cycles	

<sup>\*</sup> Meets NALFA specified criteria for usage Levels 1, 2, 3 and 4.

Class 1 RESIDENTIAL	Class 2 LIGHT COMMERCIAL	Class 3 COMMERCIAL	Class 4 HEAVY COMMERCIAL
≥ 1500 cycles	≥ 2000 cycles	≥ 4000 cycles	≥ 6000 cycles

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products.

This report, or the name of Professional Testing Laboratory, LLC, shall not be used under any circumstance in advertising to the general public.

714 Glernwood Place Dalton, GA 30721 Phone: 706-226-3283 Fax: 706-226-6787 email: protest@optilink.us